CALENDAR YEAR 2014 CONSUMER CONFIDENCE REPORT

CERTIFICATION REPORT TOWN OF ALLIGATOR

PWS ID #: 0060001

JE MATER SUPPL

2015 JUN 23 PH 1: 15

The Federal Safe Drinking Water Act requires each community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please	e Answer the Following Questions Regarding the Consumer Confidence Report
	Customers were informed of availability of CCR by: (Attach copy of publication, water bill, or other)
	☐ Advertisement in local paper
	On water bills
	Other
	Date customers were informed: 6/26/15
	CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:
	Date mailed/distributed:
	CCR was published in local newspaper. (Attach copy of published CCR and proof of publication) Name of Newspaper: Date Published:
	CCR was posted in public places. (Attach list of locations) Date posted: Lossian West Office and life that CCR was posted on a publicly accessible internet site at the address: www: Ms (rossian Neet OAH.)
	CCR was posted on a publicly accessible internet site at the address: www: Ms (ross converted to Me)
<u>CERT</u>	TIFICATION:
system correct Missis	by certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water in the form and manner identified above. I further certify that the information included in this CCR is true and it and is consistent with the water quality monitoring data provided to the public water system officials by the sippi State Department of Health, Bureau of Public Water Supply. **The (President, Mayer, Owner, etc.)** **Date** President, Mayer, Owner, etc.)** Date** Date** Date** Date**
above	consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the Public Water System and is certified only to be as true & correct as the information provided.
Su	Sas Bayetto 5-25-15
Signature	5-25-15 Date
	Mail completed form along with a copy of your CCR Report(s) before JULY 1, 2015 to:

CORRECTION PENDING

'S State Department of Health ision of Public Water Supply P O Box 1700 Jackson, MS 39215

Phone: 601-576-7518

Annual Drinking Water Quality Report Town of Alligator PWS ID # 0060001 May 2015

2015 JUN 23 PM 1: 15

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Tallahatta Formation Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of Alligator received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Bobby Brown at 662-846-0141. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 2nd Tuesday of each month at Alligator Town Hall at 6:00 p.m.

The Town of Alligator routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2014. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

				TEST RI	ESULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic C	ontamin	ants						
10. Barium	N	2014	0.0178	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	2.3	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/12 to 12/31/14	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	0.171	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	Ŋ	1/1/12 to 12/31/14	1.8	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectant	ts & Dis	infectant	By-Produ	icts				
Chlorine (as Cl2)	N	1/1/14 to 12/31/14	1.30	1.10 to 1.40	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri- halomethanes]	N	2009*	5.82 to 9.67	None	ppb	0	80	By-product of drinking water chlorination

^{*} Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Alligator is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.